



NOTES: AREA AROUND DRAIN SHOULD BE DEPRESSED/SUMPED (SEE DRAWING) TO PROMOTE POSITIVE WATER DRAINAGE.

REINFORCEMENT SHALL BE ONE SHEET EXTENDING A MINIMUM OF 300 mm BEYOND THE DRAIN FLANGE ON ALL SIDES AND SECURED IN CLAMPING RING AT DRAIN.

ALL DRAINS ARE REQUIRED TO HAVE FLASHING CLAMPING RING ASSEMBLIES. CONSULT SPECIFIC DRAIN MANUFACTURER FOR ADDL. ACCESSORIES (i.e. PERFORATED GRAVEL COLLARS, UNDERDECK CLAMPS FOR METAL DECKS, ETC.)



MONOLITHIC
 MEMBRANE
 6125
 ROOFING SYSTEMS

TYPICAL DRAIN DETAILS

HYDROTECH MEMBRANE CORP.

NO SCALE

RC-8A